


UNDERWRITERS LABORATORIES INC.®



CERTIFICATE OF COMPLIANCE


- (1)
- (2) UL Certificate Number 03.34663-2
- (3) This certificate is issued for: **Explosion/Flameproof Visual Alarm**
Type/Model: **FL.60**
- (4) Issued to: **Clifford & Snell**
 Signature Industries Ltd.
 Tom Cribb Road
 Thamesmead
 London, SE280BH England
- (5) Report Reference: **E188831, Issued: 19 January 1998**
 E188831, Issued: 20 January 1998
- (6) This product has been investigated by Underwriters Laboratories Inc.® in accordance with the following Standard(s) for Safety indicated on this Certificate:
 UL 1203, UL 1638, UL 1604,
 CSA-22.2 No. 30-M1986, CSA C22.2 No. 25-M1986, CSA C22.2 No. 157-M1987
 UL 60079-0, UL 60079-1, CSA E60079-0, CSA E60079-1
- (7) The product marking shall include the following information:
 Class I, Division 1, Groups B, C, and D; Class II, Groups E, F, and G; Class III
 Class I, Zone 1, AEx d IIB + H₂; Ex d IIB + H₂
 Class I, Division 2, Groups A, B, C, and D, T4
- (8) Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for the US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued: 06 April 2004


Paul T. Kelly
Business Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int.+ 847 664 2326 Fax: Int.+ 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>

UNDERWRITERS LABORATORIES INC.®



APPENDIX

To Certificate of Compliance 03.34663-2

This approval applies to:

Explosion/Flameproof Visual Alarm

Issued to:

Clifford & Snell
Signature Industries Ltd.
Tom Cribb Road
Thamesmead
London SE280BH England

(01) Type/Model:

Model FL.60 followed by .B; followed by .D; followed
50; followed by .A, .B, .C, .G, .O, .R, or .Y;
followed by .UL.

Electrical Ratings:

Visual Alarms: 24Vdc, 222mA, 60 fpm, 30 cd
(3cd at -35°C)

Markings include the following:

Class I, Division 1, Groups B, C and D; Class I,
Division 2, Groups B, C, and D; Class II, Groups E,
F, and G; Class III; Class I, Zone 1, AEx IIB +H₂;
Ex d IIB + H₂


This Appendix is to be used in conjunction with Certificate of Compliance No. 03.34663-2

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued:

06 April 2004


Paul T. Kelly
Business Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int.+ 847 664 2326 Fax: Int.+ 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>